



Compliance Statement

Screened Category 6A ISO/IEC, EN & ANSI/TIA Communication Cable

DINTEK Identification P/N 1105-06XXX

**Cat. 6A, Overall Braid Screened Cable with Foil Screened Twisted Pairs
100 Ω , 4 Twisted Pairs, 23 AWG, Flame Retardant, PVC, Copper Communication Cable**

DINTEK Electronic Ltd.

**5F, No. 9, Ln. 3, Minsheng W. Rd.,, Zhongshan Dist.,,
10449 Taipei City, Taiwan, R.O.C.**

Compliance Statement No. 0473-3P-1201673

This Screened ISO/IEC, EN & ANSI/TIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6A performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of ANSI/TIA-568.2-D:2018, the requirements of CENELEC EN 50288-10-1:2013, and the requirements of edition 3.0 of IEC 61156-5:2020. Flame retardancy is verified according to IEC 60332-1-2:2014. The Compliance Statement may be suspended or withdrawn if the cable fails to pass Maintenance Testing performed at 6 or 12 month intervals. The Compliance Statement is valid until 25 November 2021.

Hoersholm, 25 November 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", written over a horizontal line.

Ole Lambertsen
Test Responsible

Hoersholm, 25 November 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", written over a horizontal line.

Jens Rytter Petersen
General Manager